Clima Heating Services Ltd

Gas Warning Notice

Cert. No. 39

This form should be completed in accordance with the requirements of the current Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer	[redacted]
Company	Clima Heating Services Ltd
Address	14
	Flockton Crescent
	Sheffield
	South Yorkshire
Post Code	S13 9QR
Tel No.	[redacted]
Gas Safe Reg	[redacted]
ID Card No.	[redacted]

Job Address

Name	UoS Accommodation Village
Address	Wimberry
	Ranmoor Village
	Sheffield
Post Code	S10 3BU
Tel No.	

Client / LandLord

Name	[redacted]
Compan	Engie
Address	14
	Endcliffe Avenue
	Sheffield
	South Yorkshire
Post Code	S10 3EA
Tel No.	01142 224948
Mob. No.	

The Gas Appliance/ Gas Installation

Location (Position/Room)	Plant Room	Make	Viessmann	Type	Boiler
Model	Vitodens 200-W WB2C	Serial No.		Classification	AR - At Risk (TURNED OFF)

Gas Escape: N/A **Pipework Issue:** N/A **Ventilation Issue:** N/A **Meter Issue:** N/A **Chimn y/Flue ssue:** Yes **Other Issue**

AT RISK

The appliance(s) / installation has been classified as 'AT R K' turned off to make safe and 'DANGER DO NOT USE' label attached.

Details of Faults

Terminal too close to openable window

Actions Taken

Isolated

Actions Required

Relocate flue terminal

RIDDOR Reporting

Reported to HSE under RIDDOR 11(1) (Gas Incident) N/A

Reported to HSE under RIDDOR 11(2) (Dangerous Gas Fitting) N/A

Signatures

I confirm that I have received this Warning/ Advice Notice concerning the safety of the gas installation. I understand that the use of the appliance/ installation in the case of an IMMEDIATELY DANGEROUS or AT RISK installation, could present a hazard and could place me in breach of the Gas Safety (Installation and Use) Regulations.

Issued by: Signed [redacted]

Received by: Signed

Date 08-Nov-2021

Print Name: [redacted]

Print Name: [redacted]

The gas user was not present at the time of this visit and, where appropriate, (an IMMEDIATELY DANGEROUS (ID) or AT RISK(AR) situation) the installation has been made safe and this notice left on the premises. ☒

DANGER DO NOT USE

Gas Safe Register Contact: 0800 408 5500

Gas Emergency Services: 0800 111 999